

IAPMO RESEARCH AND TESTING, INC.

5001 E. Philadelphia St, Ontario, CA 91761-2816 (909) 472-4100 Fax: (909) 472-4244 www.iapmo.org



ANSI Accredited Program
PRODUCT CERTIFICATION



CERTIFICATE OF LISTING

IAPMO Research and Testing, Inc. is a product certification body which tests and inspects samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by authorities having jurisdiction.

Effective Date: February 2006 Void After: February 2007

Product: Chemical Dispensing Systems File No. 4902

Issued To:
Seko Dosing Systems Corp.
1103 Branagan Drive
Bristol, PA 19007






IDENTIFICATION:
Each device shall be permanently marked with the manufacturer's name or trademark, model number, and ASSE 1055 A or B. The product shall also bear the UPC® certification mark.

CHARACTERISTICS:
Chemical dispensing units manufactured with self contained means of backflow protection and classified as follows:

- Type A: Devices that include backflow protection.
Type B: Devices that include backflow protection located downstream of shut off valve or include pressure bleeding device.

To be used for mixing potable water with chemicals to provide the user with a chemical solution which is ready to use. To be installed in accordance with the manufacturer's instructions and the latest edition of the Uniform Plumbing Code.

Manufactured in compliance with ASSE 1055-1997



This listing is for the period indicated herein and is void after the date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Research Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Reproduction of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc.


Any alteration of this certificate could be grounds for revocation of the listing.

Robert R. Simson

Chairman, Product Research Committee

Ron Chaney

Executive Director



IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING

Page 2

Effective Date: February 2006 Void After: February 2007
Product: Chemical Dispensing Systems
Issued To: Seko Dosing Systems Corp. File No. 4902
MODELS: Promix A-Gap Dispensing System
 Promix F-Gap Dispensing System

Sponsor of the Uniform Plumbing Code™, Uniform Mechanical Code™,
Uniform Swimming Pool, Spa, and Hot tub Code™,
and Uniform Solar Energy Code™